

NOTES:

- 1. IF SLAB IS LESS THAN 12" THICK, ANCHOR BOLTS SHALL EXTEND THROUGH SLAB AND BE BACKED UP WITH 4" X 3/16" (MIN) SQUARE WASHERS.
- 2. CHANNELS SHALL BE LEVELED AT TIME CONCRETE IS CAST.
- 3. CHANNELS SHALL HAVE HOLE FOR ANCHOR BOLTS TO EXTEND THROUGH.

TYPICAL FLOOR MOUNTING AND GROUNDING FOR MOTOR CONTROL CENTERS, CONTROL PANELS, SWITCHGEAR AND FREE STANDING EQUIPMENT

LBNL ELECTRICAL STANDARDS	DRAWN BY	DATE
	CHECKED BY	
GROUNDING	APPROVED BY	
TYPICAL FLOOR MOUNTING AND GROUNDING	CAD FILE PATH	
	SCALE NTS	
UNIVERSITY OF CALIFORNIA LAWRENCE BERKELEY NATIONAL LABORATORY	DRAWING NO.	SHEET
FACILITIES DIVISION	GRD113	
TAGILITIES DIVISION	PROJECT NO.	1 1